

From: [Moore, Gary](#)
To: [Jonathan Carroll](#)
Cc: [Steven Wilson](#); [Arredondo Alonzo](#)
Bcc: [Mueller, Brian](#)
Subject: RE: Proposal- Lazarus/Ingleside Tank 16 Revision 6
Date: Wednesday, September 11, 2013 7:42:38 AM

Jonathan:

Below is what I asked for on August 15, it appears that work is progressing on Tank 16 without providing me the information that I requested or acknowledging the items below and how LTR1 intends on handling these items.

There has been a previous acknowledgement that there were holes in the tank bottom that were filled with fiberglass. That would indicate that there is likely contamination below the tank bottom. If you are cutting out portions of the tank bottom to repair, these soils below the tank should be inspected, monitored, and sampled. Remember, there are no liners below these tanks (my understanding) and the soil in the area is primarily sand with a high ground water table.

Thanks

Gary Moore

Federal On-Scene Coordinator

U.S. EPA Region 6

214-789-1627 cell

214-665-6609 office

moore.gary@epa.gov

From: Moore, Gary
Sent: Thursday, August 15, 2013 2:03 PM
To: Jonathan Carroll
Cc: Steven Wilson; Arredondo Alonzo
Subject: RE: Proposal- Lazarus/Ingleside Tank 16 Revision 6

Jonathan:

I do not follow what is to be done with Tank 16. There are so many revisions that I am unable to follow. I need to see a list of those things that are planned for this tank. I do not see the following:

- 1. An certified inspection by a licensed inspector to determine what all is necessary and/or recommended to put this tank(s) back into service;**
- 2. Any discussion of how to handle potentially contaminated soils below the tank (assessment, removal, etc.); Let me know what you plan on doing in this regard.**
- 3. Tank Fit For Service Certification by a Licensed Professional Engineer;**

I need a response ASAP.

Gary Moore



9568240

Federal On-Scene Coordinator
U.S. EPA Region 6
214-789-1627 cell
214-665-6609 office
moore.gary@epa.gov

From: Jonathan Carroll <JCarroll@lazarusenergy.com>
Sent: Thursday, August 15, 2013 11:17 AM
To: Moore, Gary; Moore, Gary
Cc: Steven Wilson
Subject: Fw: Proposal- Lazarus/Ingleside Tank 16 Revision 6

FYI

----- Forwarded Message -----

From: Andy Martin <ajm@bbbtanksvc.com>
To: Jonathan Carroll <JCarroll@lazarusenergy.com>
Cc: Jacob Swain <jacobswain@bbbtanksvc.com>; bobswain@bbbtanksvc.com
Sent: Wednesday, August 14, 2013 8:43 AM
Subject: Proposal- Lazarus/Ingleside Tank 16 Revision 6

Jonathan – Please see attached per our discussion last night. Lets meet Thursday or Friday and discuss all the priority items. I have meetings this morning from 10-1 but available before and after at your earliest convenience.

Andrew "Andy" J. Martin
Director
BBB Tank Services, Inc.
162 Independence Pkwy N
Baytown, Texas 77520
Office: 832.695-2132
Fax: 281.838-8748
Cell: 832.724.3149
ajm@bbbtanksvc.com
www.bbbtankservices.com